



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.: FSR/0125186221200015

Date : 02-01-2026

From :
Director
Fire Prevention Wing
West Bengal Fire & Emergency Services

To :
BISHOP GEORGE MISSION SCHOOL
MOUZA-KALIKAPUR, J.L.-100, C.S.DAG NO.-2329, R.S.DAG.-2346,2348, C.S.KHATIAN NO.-488, R.S.KHATIAN NO.-
678, UNDER PRANGANJ GRAM PANCHAYET, BHANGAR-I PANCHAYET SAMITY, P.S-BHANGAR, DIST.-SOUTH 24
PARGANAS, PIN-743 502.

Sub : Revised Fire Safety Recommendation for proposed two storied school building within the premises of an
Existing two storied school building under group educational building at the Premises No. Mouza-Kalikapur, J.L.
No. -100. C.S. DAG No. – 2329, R.S. DAG No. 2346, 2348, R.S. Kha. No. 678, L.R. Khatian No. 4922, under Pran Ganj
Gram Panchayet, Bhanar(I) Panchayet Samity, P.S.- Bhanagar, Dist.: 24 Parganas(S)..

This is in reference to your AIN 211882506300002653 dated 06-Dec-2025 regarding the Revised Fire Safety Recommendation for proposed two storied school building within the premises of an Existing two storied school building under group educational building at the Premises No. Mouza-Kalikapur, J.L. No. -100. C.S. DAG No. – 2329, R.S. DAG No. 2346, 2348, R.S. Kha. No. 678, L.R. Khatian No. 4922, under Pran Ganj Gram Panchayet, Bhanar(I) Panchayet Samity, P.S.- Bhanagar, Dist.: 24 Parganas(S)..

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In
returning one set of plan with recommendation, this office is issuing Revised Fire Safety Recommendation in
favor of the aforesaid building subject to the compliance of the

Recommendation :

Fire Safety Recommendation which was issued earlier from this office vide memo no: FSR/0125186221200015 Dated: 28/02/2022 shall be followed strictly for this building



Signature valid

Digitally Signed.
Name: SHYAM CHANDRA MONDAL
Date: 02-Jan-2026 16:45
Reason: D-Sign
Location: E-Dist 210

Director

West Bengal Fire and Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211882506300002653



**Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16**

Memo no.:FSR/0125186221200015

Date: 09-07-2022

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: M/S BENEDICTION EDUCATION SERVICES PVT. LTD.
MOUZA-KALIKAPUR, J.L.-100, C.S.DAG NO.-2329, R.S.DAG.-2346,2348, C.S.KHATIAN NO.-488, R.S.KHATIAN NO.-
678, UNDER PRANGANJ GRAM PANCHAYET, BHANGAR-I PANCHAYET SAMITY, P.S-BHANGAR, DIST.-SOUTH 24
PARGAN

Sub: Fire Safety Certificate for an existing construction of G+I storied under group of Educational Building in the name of Bishop George Mission School Ghatakpur under Benediction Education Services Pvt. Ltd. at Mouza- Dakshin Kalikapur under Pranganj Gram Panchayet, P.S-Bhangar, Dist- South 24 parganas, West Bengal, PIN-743502.

This is in reference to your application no. 0125189221200080 dated 27-04-2022 regarding the Fire Safety Certificate for an existing construction of G+I storied under group of Educational Building in the name of Bishop George Mission School Ghatakpur under Benediction Education Services Pvt. Ltd. at Mouza- Dakshin Kalikapur under Pranganj Gram Panchayet, P.S-Bhangar, Dist- South 24 parganas, West Bengal, PIN-743502.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1.The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
- 2.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- 3.Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
- 4.A Fire control room shall be put up at the Ground floor.
- 5.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the Building.
- 6.The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189221200080.

Page : 1

- 7.If required the old electrical line shall have to be replaced with new lines, the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 8.Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 9.First-Aid Fire Fighting system shall be provided as per I.S. Specification.
- 10.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
- 11.Periodical flashing of water in the Hydrants shall be made to maintain the efficient working performance of above mention system.
- 12.This 'Fire Safety Certificate' is valid for three years and has to be renewed after stipulated time period given from the Director General West Bengal fire & Emergency Service.

Note: This certificate is computer generated with digital signature and does not require any seal in original. The authenticity of this certificate can be verified at <https://eservices.wb.gov.in> (Third Party verification report)

Signature valid

Digitally signed by ABHIJIT
PANDEY
Date: 2022.07.09 20:18:42 IST

Director
West Bengal Fire & Emergency Services