



Government of West Bengal
Public Health Engineering Directorate
Office of the Executive Engineer, Alipore Division
45, Ganesh Chandra Avenue, (5th Floor), Kolkata - 700013

Memo No. 2289 /AD


Date 15.05.2025

TO WHOM IT MAY CONCERN

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Certified that I Sri Subhash Chandra Shah, Assistant Engineer, HQ-II Alipore Division, Public Health Engineering Dte. inspected **Bishop George Mission School, at Ghatakpur, Dakshin Klikapur, Gobindapur, South 24 Parganas. Pin 743502** on 15.05.2025 and found that the school is maintaining the hygienic sanitation in their Toilet Blocks and Washrooms with proper regular day to day cleaning with trained house-keeping staffs and also condition in the school building & the campus as per the norms prescribed by the Central/State/U.T.Govt. Water samples were collected from both overhead storage reservoir as well as drinking water taps which were tested in our State sponsored NABL accredited, District Water Testing laboratory and found the drinking water to be safe and potable as per WHO/ CPHEEO standard.

The above certificate is valid for a period of **2 (two) years** from date of issue of this certificate subjected to regular testing of drinking water sample every six months from any recognized laboratory or our laboratory and engagement of housekeeping staff & pest control on regular basis as applicable.


(Subhash Chandra Shah)
Assistant Engineer, HQ-II
Alipore Division,
PHE Dte.

APPENDIX-VIII

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No 05-2289/AD/2025

Date 15.05.2025

It is certified that an inspection team headed by Sri Subhash Chandra Shah, Assistnt Engineer, H.Q. II (Name of Officers With designation) from Public Health Engineering Dte. Alipore Division (Name of Department /Office) inspected **Bishop George Mission School, at Ghatakpur, Dakshin Klikapur, Gobindapur, South 24 Parganas. Pin 743502 on 15.05.2025** has found safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.TGovt.

The above valid for a period of **02 (Two) years** from dated **15.05.2025**.


Assistant Engineer (HQ-II),
Alipore Division
P.H. Engg. Dte.
Govt. of West Bengal

Signature with Seal : _____

Name

: SUBHASH CHANDRA SHAH

Designation

: ASSISTANT ENGINEER

To,
The Principal,
Bishop George Mission School,
Ghatakpur, Dakshin Klikapur,
Gobindapur,
South 24 Parganas. Pin 743502.

SOUTH 24 PARGANAS DISTRICT WATER TESTING LABORATORY
(UNDER ALIPORE DIVISION PHE DTE.)
GOVERNMENT OF WEST BENGAL
BIJOYGARH STATE GENERAL HOSPITAL COMPLEX
KOLKATA-700032

TEST REPORT

Ref Memo No: B.G.M.S 176 dt.28.07.2026
GRN: 192026270161409678, (1/1) dt. 28.07.2026
Sample Sending Authority/Person: - B.G.M.S.

Date of Reporting: - 29.07.2026

Location: - Bishop George Mission School Premisess
Ghatakpukur, Mouza-S-Kalikapur, P.O.-Gobindapur, Bhangor

Date of Sampling: - 28.07.2026

Sample Received on: - 28.07.2026

Sample Collected by: School Representative
Sample ID No.: - 1/RW

Type of Sample- Drinking Water


Analysis: - Date of Starting: - 28.07.2026

Date of Completion: - 29.07.2026


-: Physical, Chemical & Bacteriological Test Findings: -

Sl.No.	Parameter	Desirable Limit*	Permissible Limit in absence of alternate Source*	Treated Water Result
1.	pH	6.5	8.5	7.49
2.	Turbidity (NTU)	1	5	0.51
3.	Total Hardness (as CaCO ₃), mg/L	200	600	9.96
4.	Chloride (as Cl ⁻), mg/L	250	1000	4.99
5.	Iron (as Fe) mg/L	1.0	No Relaxation	0.08
6.	Arsenic (as As) mg/L	0.01	No Relaxation	BDL
7.	Manganese (as Mn), mg/L	0.10	0.30	BDL
8.	Total Dissolved Solids (mg/L)	500	2000	41
9.	Total Coliform (CFU/100ml)	Absent	Absent	Not Found
10.	Fecal Coliform (CFU/100ml)	Absent	Absent	Not Found

* Drinking Water – Bureau of Indian Standards (BIS) IS: 10500:2012, Drinking Water Specification. 2012(Amendment No.1, June 2015).
Note: BDL= Below Detection Limit.


Bacteriologist
District Laboratory


Chemist
District Laboratory


Junior Engineer (RWS)
PHEDte.


Assistant Engineer (RWS)
PHEDte.